

# Hydrogen Workshop

Paris-Saclay, 08/11/2018

## Risk assessment of impurities in hydrogen for fuel cell

*Martine Carré / Fabien Auprêtre*




## Outline

1. Objectives
2. H<sub>2</sub> source: PEM Electrolysis
3. H<sub>2</sub> source: Steam Methane Reforming
4. Conclusion





- **Production site**
- **SMR\***
- **Electrolysis**



- **Transport**
- **GH2**
- **LH2**



- **Point of use**
- **Automotive and**
- **Stationary applications**

Purity analysis

## Hydrogen

### ▪ **Task 1.1: Assessment of probability of impurities existing in real samples of hydrogen**

#### **Objectives:**

- assessment of the possible impurities that could be produced at the different stages of the hydrogen production process ;
- provide the overall probability of these impurities being present in the end-product hydrogen (following purification steps);
- 3 processes: steam methane reforming, electrolysis and chlor-alkali processes.

### ▪ **Task 1.2: Assessment of impact of impurities to fuel cell system**

#### **Objectives:**

- assess the impact of multiple impurities in hydrogen on fuel cells.

1- Assessment of the presence of impurities in H<sub>2</sub> produced with PEM electrolysis and SMR processes based on risk assessment approach

2- Analytical campaign of PEM electrolysis and SMR production sites

### ▪ **Task 1.3: Risk assessment**

#### **Objectives:**

perform a risk assessment of impurities in fuel cell hydrogen.


# PEM Electrolysis

THIS DOCUMENT IS **Public**

Date 2018-11-08

Martine Carré (Air Liquide) - Fabien Auprête (AH2GEN)


Risk assessment of impurities in Hydrogen



*Design of AH2GEN's PEM Water Electrolyser process with TSA*

General classification of impurities for PEM electrolysis + H<sub>2</sub> purification

<b>Probability of presence of impurity</b>	<b>Impurity</b>
Frequent	O <sub>2</sub> , H <sub>2</sub> O
Possible	N <sub>2</sub>
Rare	
Very Rare	CO <sub>2</sub>
Unlikely	He, Ar, CO, CH <sub>4</sub> , sulfur compounds, ammonia, THC (except methane), formaldehyde, formic acid, Halogenated compounds



THIS DOCUMENT IS **Public**

Date 2018-11-08

Martine Carré (Air Liquide) - Fabien Auprête (AH2GEN)

Risk assessment of impurities in Hydrogen






Table 5: Risk assessment table for PEM WE +TSA

Contaminant	Threshold [µmol/mol]	Possible cause for the source studied	Existing barrier			P*	P	S	C	
Inert gas: N <sub>2</sub>	100	Air intake into pure water tank at anodic side during normal operation	Operating conditions applied in anodic separator tank	PEM membrane (low cross over through the membrane)		0			Green	
		N <sub>2</sub> use for venting during emergency shut down and/or maintenance	Gas production temporary vented after restart for certain period of time (factory setting)			2	2	1		
		Leakage of H <sub>2</sub> inerting valve (N <sub>2</sub> used as inerting gas)	H <sub>2</sub> operating pressure > N <sub>2</sub> pressure supply			1				
		Leakage of pneumatic valves (N <sub>2</sub> used as actionning gas)				1				
Inert gas: Ar	100	Not expected to be present.				0	0	1	Green	
Oxygen	5	O <sub>2</sub> normally generated at the anodic side of cell stack and O <sub>2</sub> cross over through the PEM membrane TSA malfunction	Deoxo of TSA Temperature overshoot if O <sub>2</sub> content too high. Temperature measurement + trip 1°C >50°C	Analysis + trip at xx ppm at TSA outlet xx < 5 ppm	Gas production temporary vented after restart for certain period of time (factory setting)	2	2	0	Green	
Carbon dioxide	2	from tap water at anodic side	Reverse osmosis purification unit	anodic separator tank	ion exchange resin in closed water loop	PEM membrane (low cross over through the membrane)	1		1	Green
		from air into PWT at anodic side	CO <sub>2</sub> filter on pure water tank air intake	anodic separator tank	ion exchange resin in closed water loop	PEM membrane (low cross over through the membrane)	1	1	1	
Carbon monoxide	0.2	Not expected to be present.				0	0	2	Green	
Methane (CH <sub>4</sub> )	100	Not expected to be present.				0	0	1	Green	
<b>Water</b>		reactant --> permeation through PEM membrane due to electro-osmosis + H <sub>2</sub> water saturated at 60°C TSA malfunction	TSA dryer	DP Analysis + trip at xx ppm at TSA outlet xx < 5 ppm	Gas production temporary vented after restart for certain period of time (factory setting)	2	2	4	Red	
Total sulphur compounds	0.004	Materials gaskets, valve seats releasing ppb level of sulfur compound	Material specifications			0	0	4	Green	
Ammonia	0.1	from tap water at anodic side	Reverse osmosis purification unit	PEM membrane (no transfer through the membrane)		0	0	4	Green	
Total hydrocarbons	2	Not expected to be present.				0	0	4	Green	
Formaldehyde	0.01	Not expected to be present.				0	0	2	Green	
Formic acid	0.2	Not expected to be present.				0	0	2	Green	
Helium	300	Not expected to be present.				0	0	0	Green	
Halogenated compounds	0.05	from tap water at anodic side	Reverse osmosis purification unit			0	0	4	Green	


## Occurrence class for each impurities

- Occurrence class 4 (highest probability) :
- Occurrence class 3 :
- Occurrence class 2: N<sub>2</sub>, O<sub>2</sub>, H<sub>2</sub>O
- Occurrence class 1: CO<sub>2</sub>
- Occurrence class 0 (never observed): Ar, CO, CH<sub>4</sub>, He, halogenated products, formaldehyde, formic acid, THC, ammonia, sulfur compounds

## ELYTE E12-15 PEM electrolyzer



- H<sub>2</sub> flow rate: 12 Nm<sup>3</sup>/h
- Operating pressure:
  - H<sub>2</sub>: 15 bar
  - O<sub>2</sub>: 14 bar
- Operating temperature: 60°C
- TSA purification unit
  - H<sub>2</sub>: 99,998%
  - O<sub>2</sub> < 10 ppm
  - H<sub>2</sub>O < 10 ppm




Samples 1 to 3 : before H<sub>2</sub> purification unit

Compounds	Unit	Results with expanded uncertainty (k=2)		NMI
		Sample 4-1	Sample 4-2	
CO	μmol/mol	< 0.01	< 0.01	NPL
CO <sub>2</sub>	μmol/mol	< 5	< 5	SP
CO <sub>2</sub>	μmol/mol	0.240 ± 0.012	0.221 ± 0.011	NPL
CH <sub>4</sub>	μmol/mol	0.091 ± 0.007	0.086 ± 0.008	NPL
Non methane hydrocarbons	μmol/mol	< 0.01	< 0.01	NPL
H <sub>2</sub> O	μmol/mol	> 100	> 100	NPL
Total sulphur compounds	μmol/mol	< 0.0036	< 0.0036	NPL
O	μmol/mol	Not analysed	Not analysed	CEM
O <sub>2</sub> + Ar	μmol/mol	< 25	< 30	SP
O <sub>2</sub>	μmol/mol	20.9 ± 3.0	23.3 ± 3.8	NPL
N <sub>2</sub>	μmol/mol	< 90	< 130	SP
N <sub>2</sub>	μmol/mol	Not analysed	Not analysed	CEM
N <sub>2</sub>	μmol/mol	< 1.2	< 1.2	NPL
Ar	μmol/mol	Not analysed	Not analysed	CEM
Ar	μmol/mol	< 0.5	< 0.5	NPL
Total halogenated (HCl)	μmol/mol			VSL
CH <sub>2</sub> O	μmol/mol			VSL
CH <sub>2</sub> O <sub>2</sub>	μmol/mol			VSL
NH <sub>3</sub>	μmol/mol			VSL
He	μmol/mol	< DL	< DL	CEM

▶ Water saturated samples (DP= 7°C / 15 bar)

▶ Low O<sub>2</sub> content (stability?)

► **Samples 4 to 6: O<sub>2</sub> content in accordance with specification but high water content**



► **Samples 7 to 9:**

- ◆ H<sub>2</sub>O content in accordance with specification < 2 ppm
- ◆ O<sub>2</sub> content in accordance with specification < 5 ppm

Samples 7 to 9 : after TSA purification unit

Compounds	Unit	Results with expanded uncertainty (k=2)			NMI
		Sample 4-1	Sample 4-2	Sample 3	
CO	µmol/mol	< 0.02	< 0.02	< 0.02	NPL
CO <sub>2</sub>	µmol/mol	< 5	n.a.	< 5	RISE
CO <sub>2</sub>	µmol/mol	< 0.01	< 0.01	< 0.01	NPL
CH <sub>4</sub>	µmol/mol	< 0.01	< 0.01	< 0.01	NPL
Non methane hydrocarbons	µmol/mol	0.156 ± 0.030	0.126 ± 0.026	0.111 ± 0.024	NPL
H <sub>2</sub> O	µmol/mol	< 0.8	< 1.2	< 3	NPL
Total sulphur compounds	µmol/mol	< 0.0030	< 0.0030	< 0.0030	NPL
O <sub>2</sub>	µmol/mol	< 5	n.m.	< 5	CEM
O <sub>2</sub> + Ar	µmol/mol	< 25	n.a.	< 25	RISE
O <sub>2</sub>	µmol/mol	1.39 ± 0.36	< 0.5	1.59 ± 0.45	NPL
N <sub>2</sub>	µmol/mol	< 100	n.a.	< 100	RISE
N <sub>2</sub>	µmol/mol	< 80	n.m.	n.m.	CEM
N <sub>2</sub>	µmol/mol	1.51 ± 0.2	< 1.0	1.86 ± 0.2	NPL
Ar	µmol/mol	< 80	n.m.	n.m.	CEM
Ar	µmol/mol	< 0.5	< 0.5	< 0.5	NPL
Total halogenated (HCl)	µmol/mol	n.a.	< 0.005	< 0.005	VSL
CH <sub>2</sub> O	µmol/mol	< 0.005	< 0.005	< 0.005	VSL
CH <sub>2</sub> O <sub>2</sub>	µmol/mol	< 0.1	< 0.1	< 0.1	VSL
NH <sub>3</sub>	µmol/mol	n.a.	n.a.	n.a.	VSL
He	µmol/mol	< 9	< 9	< 9	CEM


# Steam Methane Reforming + PSA

THIS DOCUMENT IS **Public**

Date 2018-11-08

Martine Carré (Air Liquide) - Fabien Auprête (AH2GEN)

Risk assessment of impurities in Hydrogen





## PSA technology:


- Based on adsorbent technology:
  - Multiple adsorbents: silica, alumina, molecular sieves, activated carbons.
  - Adsorb different kind of gases
- Better quality of H<sub>2</sub> is produced compared to other purifications process

(between 99% to 99.9%)

### RELATIVE STRENGTH OF ADSORPTION

+	++	+++	++++
<b>He</b>	<b>Ar</b>	<b>CO</b>	<b>C<sub>3</sub>H<sub>6</sub></b>
<b>H<sub>2</sub></b>	<b>O<sub>2</sub></b>	<b>CH<sub>4</sub></b>	<b>C<sub>4</sub>H<sub>8</sub></b>
	<b>N<sub>2</sub></b>	<b>CO<sub>2</sub></b>	<b>C<sub>5</sub>+<sup>+</sup></b>
		<b>C<sub>2</sub>H<sub>6</sub></b>	<b>H<sub>2</sub>S</b>
		<b>C<sub>2</sub>H<sub>4</sub></b>	<b>NH<sub>3</sub></b>
		<b>C<sub>3</sub>H<sub>8</sub></b>	<b>H<sub>2</sub>O</b>

 <p>Strength + ↓ -</p>	<p><b>Alumina</b></p> <p><b>Carbon Prefilter</b></p> <p><b>Activated Carbon</b></p> <p><b>Molecular Sieve</b></p>
---	---

Contaminant	Threshold	Causes possible For the source studied	Existing barriers						P
Inert gases : N2	100	Present in Nat gas and Syngas PSA malfunction	PSA	Double analysis + trip at xx ppm at PSA outlet xx<100 ppm					3
Inert Gas Ar		Only ATR and POx Present in O2 typical 0.6% in Syngas	PSA. Not sized to remove Argon. Argon content may be						2
Oxygen	5	Not present in Syngaz Oxygen is unstable in the condition of reforming and	PSA cannot be used with significant O2 content for safety reasons						0
Carbon dioxide	2	Present in Syngas (%)	PSA Adsorption strength of MS, Activated carbon, Silicagel						0
Carbon monoxide	0,2	Normal operation below threshold. Occasional peaks at ppm level	Double analysis + trip at xx ppm at PSA outlet (xx<10)						4
Methane (CH4)	100	Present in Syngas at % level	In most cases CO is sizing the PSA, therefore CO<10ppm ==> CH4 < xx						2
Water	5	Syn gas saturated in H2O	PSA Adsorbed in Alumina and MS Adsorption strength						0
Total sulphured components	0,004	Sulfur from Nat Gas	Desulfuration upstream reformer (typical values) Normal < 10 ppb	Prereformer Catalyst poisoning by sulfur irreversible	Reformer Catalyst poisoning by sulfur irreversible	Shift Catalyst poisoning by sulfur irreversible	PSA Adsorption of H2S before CO,	H2S Adsorption in pipe and vessels	0
Ammonia	0,1	Traces present in Syngas.	PSA, Adsorption strength of Alumina, MS Higher than						0
Total hydrocarbons	2	Traces of C2+ after reforming reaction	PSA C2 C3, C4, C5+ adsorbed by Activated Carbon layer						0
Formaldehyde	0,01	Idem Acide Formique... Arreté par PSA	PSA, Adsorption strength of Alumina, MS Higher than						1
Formic acid	0,2	May be present in Syngas essentially liquid	PSA, Formic Adsorption strength of Alumina, MS Higher than						0
Halogenated compounds	0,05	Present in Nat Gas?	Any Cl present in Nat gas would be stopped by HDS	Prereformer Catalyst poisoning by Cl irreversible	Reformer Catalyst poisoning by Cl irreversible	Shift Catalyst poisoning by Cl irreversible	PSA Adsorption of Cl before CO, CO2,		0
Helium	300	Not present in Nat Gas in N Europe (<10 ppm) Passes through the whole.							0

Occurrence class	impurities
4	CO
3	N <sub>2</sub>
2	Ar, CH <sub>4</sub>
1	Formaldehyde
0	CO <sub>2</sub> , He, H <sub>2</sub> O, halogenated products, formic acid, THC, ammonia, sulfur compounds

Compounds	Unit	Results with expanded uncertainty (number of different samples: 3 and <i>k</i> =2)
CO	μmol/mol	< 0.01
CO <sub>2</sub>	μmol/mol	< 0.01
CH <sub>4</sub>	μmol/mol	< 0.01
Non methane hydrocarbons	μmol/mol	< 0.01
H <sub>2</sub> O	μmol/mol	< 0.5
Total sulphur compounds	μmol/mol	< 0.0036
O <sub>2</sub>	μmol/mol	< 0.5
N <sub>2</sub>	μmol/mol	< 1.2
Ar	μmol/mol	< 0.5
Total halogenated (HCl)	μmol/mol	< 0.005
CH <sub>2</sub> O	μmol/mol	< 0.005
CH <sub>2</sub> O <sub>2</sub>	μmol/mol	< 0.1
NH <sub>3</sub>	μmol/mol	< 0.1
He	μmol/mol	< 50
Compounds	Unit	Results with expanded uncertainty (number of different samples: 3 and <i>k</i> =2)
C2 hydrocarbons	μmol/mol	< 0.5
C3-hydrocarbons	μmol/mol	<1
C4-hydrocarbons	μmol/mol	<1
C5-hydrocarbons	μmol/mol	<1
C6 – C18 hydrocarbons	μmol/mol	<0.05

For all the samples taken at SMR + PSA process:

→ all impurities are below the detection limit of analytical methods

# Conclusion

THIS DOCUMENT IS **Public**

Date 2018-11-08

Martine Carré (Air Liquide) - Fabien Auprête (AH2GEN)

Risk assessment of impurities in Hydrogen

- The main impurities are identified for both PEM electrolysis and SMR processes
- The analysis of samples from PEM electrolyzer and SMR confirmed the risk assessment
- Appropriate actions and barriers can be added to reduce the risk if necessary

For more details, see the publication:

INTERNATIONAL JOURNAL OF HYDROGEN ENERGY XXX (2018) 1–12



ELSEVIER

Available online at [www.sciencedirect.com](http://www.sciencedirect.com)

ScienceDirect

journal homepage: [www.elsevier.com/locate/he](http://www.elsevier.com/locate/he)



## Probability of occurrence of ISO 14687-2 contaminants in hydrogen: Principles and examples from steam methane reforming and electrolysis (water and chlor-alkali) production processes model

Thomas Bacquart <sup>a,\*</sup>, Arul Murugan <sup>a</sup>, Martine Carré <sup>b</sup>, Bruno Gozlan <sup>b</sup>,  
Fabien Auprêtre <sup>c</sup>, Frédérique Haloua <sup>d</sup>, Thor A. Aarhaug <sup>e</sup>

Thank you for your attention

